

## FOOD TRUCK INSPECTION

Vehicle has registration from the DMV.

Maximum of one (1) 100lb tank.

Tanks do not appear to contain leaks and are not damaged.

No gasoline generators with separate fill (not filled from vehicle fuel tank).

Generators and LPG storage compartments located on exterior are enclosed.

Bumper extends beyond the LPG storage a min 6" or stored at the appropriate height min 6".

LPG storage compartments are vented outside the vehicle.

Fuel Tanks and Cylinders are not stored inside the vehicle.

Belly tanks are stored with vehicle body frame for additional structural protection.

Commercial kitchen hood/suppression system installed for grills, stove or fryolator.

Adjacent grills, stoves, fryolators have 16" space between them or 8" noncombustible shields.

Hood and exhaust system are clean.

Class K extinguisher and a 20 BC extinguisher installed.

All piping to gas appliances and hood suppression systems professionally installed.

